

**2019 Annual Water Quality Report
(Testing Performed January through December 2018)**

TROY UTILITIES DEPARTMENT

PWSID AL0001124

301 Charles W. Meeks Avenue

P. O. Box 549

Troy, AL 36081

Phone 334-566-0177

Fax 334-808-7404

The Troy Utilities Department is pleased to present this Annual Water Quality Report to inform you about the quality of the water delivered to you. We work diligently to provide a high quality, cost effective drinking water supply.

Water Sources	6 groundwater wells producing from the Ripley and Tuscaloosa aquifers	
Inter-Connections	Emergency connection with Pike County Water	
Water Treatment	Chlorination for disinfection Fluoridation at wells 3 and 4 for tooth health	
Storage Capacity	Seven elevated storage tanks with a total capacity of 4.75 million gallons	
Number of Customers	Approximately 7500 metered service connections	
Assistant General Manager	Mike Davis	
City Council	Jason A. Reeves, Mayor	Greg Meeks, District 2
	Marcus Paramore, President, District 3	Stephanie Baker, District 4
	Robert Jones, District 1	Wanda Moultry, District 5

Source Water Assessment

Troy Utilities has completed all of the components of the required Source Water Assessment Plan (SWAP) in accordance with the Alabama Department of Environmental Management (ADEM) regulations. This plan assists with protecting our water sources. The plan provides information such as the delineation of wellhead protection areas and potential sources of contamination within these areas. It also includes a susceptibility analysis which classifies potential contaminants as high, moderate or non-susceptible (low) to contaminating the water source. The SWAP is updated as needed.

The SWAP report is available in our office for review, or you may request a copy. Please help us protect our source water. Carefully follow instructions on pesticides and herbicides you use for your lawn and garden and properly dispose of household chemicals, paints and waste oil.

Information about Lead

Elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. However, *lead is rarely found in source water*. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Troy Utilities is responsible for providing high quality drinking water, but cannot control the variety of materials used in home plumbing components. The more time water has been sitting in pipes, the more dissolved metals, such as lead, it may contain. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

Only use water from the cold-water tap for drinking, cooking, and especially for making baby formula. Lead in household water usually comes from the plumbing in your house, not from the local water supply, and hot water is more likely to cause lead to leach from plumbing materials. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available online at <https://www.epa.gov/your-drinking-water/basic-information-about-lead-drinking-water> or by calling the EPA's Safe Drinking Water Hotline at 1-800-426-4791.

Questions?

If you have any questions about this report or concerning Troy Utilities, please contact Mike Davis, Assistant General Manager, at 334-566- 0177. We want our valued customers to be informed about their water utility. Council meetings are held on the second and fourth Tuesday of each month at 5:00 p.m. at Troy City Hall, 301 Charles W. Meeks Avenue, Troy, Alabama.

More information about contaminants in drinking water and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 1-800-426-4791.

General Information

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Maximum Contaminant Levels (MCLs), defined in a List of Definitions in this report, are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals and from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water run-off, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Some individuals may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, those who have undergone organ transplants, individuals with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. Individuals at risk should seek advice about drinking water from their health care providers.

Surface water sources are tested for pathogens such as *Cryptosporidium* at certain intervals determined by the EPA and the ADEM. These pathogens can enter the water from animal or human waste. All test results were well within Federal and State standards. For people who may be immuno-compromised, a guidance document developed by the Center for Disease Control is available online at <http://nepis.epa.gov/Exe/ZyPURL.cgi?Dockey=200024LD.txt> or from the Safe Drinking Water Hotline at 1-800-426-4791. This language does not indicate the presence of *Cryptosporidium* in our drinking water.

Based on a study conducted by ADEM with the approval of the EPA, a statewide waiver for the monitoring of asbestos and dioxin was issued. Thus, monitoring for these contaminants was not required.

Monitoring Schedule

Troy Utilities' water sources are routinely monitored for contaminants according to a schedule determined by Federal and State regulations, using EPA-approved methods and State-certified laboratories. Every water system has individually assigned monitoring requirements. The ADEM allows monitoring of some contaminants less than once per year because the concentrations of these contaminants do not change frequently. The following table shows the most recent year of monitoring for these contaminant groups.

Constituents Monitored	Year Monitored
Inorganic Contaminants	2016
Lead/Copper	2016
Microbiological Contaminants	Monthly
Nitrates	2018
Radioactive Contaminants	2016
Synthetic Organic Contaminants (including pesticides & herbicides)	2016
Volatile Organic Contaminants	2016
Disinfection By-products	2018
Unregulated Contaminants Monitoring Rule 4 (UCMR4) Contaminants	2018
Distribution System Evaluation (DSE) Disinfection By-products	2018

Monitoring Results

This report contains results from the most recent monitoring of primary, secondary, and unregulated contaminants. The monitoring was performed in accordance with the sampling requirements established by EPA and ADEM. We have learned through our monitoring and testing that some constituents have been detected. We are pleased to report that our drinking water meets or exceeds federal and state drinking water requirements.

DETECTED DRINKING WATER CONTAMINANTS						
Regulated Primary Contaminants	Violation Y/N	Level Detected	Unit Msmt	MCLG	MCL	Likely Source of Contamination
Chlorine residual	NO	0.20-2.70	ppm	MRDLG=4	MRDL=4	Water additive used to control microbes
Total coliform bacteria	NO	positive samples in Mar. & Nov. 2018 *	Present or Absent	0	presence in 5% of monthly samples	Naturally present in the environment
Turbidity	NO	0.11-0.51	NTU	n/a	TT	Soil runoff
Combined radium	NO	3.29	PCi/l	0	5	Erosion of natural deposits
Copper	NO	0.105 ** 0 > AL	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride	NO	0.16-0.95	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from factories
Lead	NO	1.10 ** 0 > AL	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen)	NO	ND-0.21	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of deposits
Selenium	NO	ND-0.32	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
TTHM [Total trihalomethanes]	NO	LRAA Range 3.18-9.92	ppb	0	80	By-product of drinking water chlorination
HAA5 [Total haloacetic acids]	NO	LRAA Range 0.92-1.67	ppb	0	60	By-product of drinking water chlorination
Unregulated Contaminants						
Chloroform	NO	ND-0.81	ppb	n/a	n/a	Naturally occurring in the environment or as a result of industrial discharge or agricultural runoff
1, 2, 3- Trichlorobenzene	NO	ND-0.35	ppb	n/a	n/a	Likely occurred as a carry-over from a lab standard.
Secondary Contaminants						
Alkalinity	NO	0.147-0.199	ppm	n/a	n/a	Caused by carbonates, bicarbonates and hydroxides. Phosphates and silicates contribute
Aluminum	NO	ND-0.03	ppm	n/a	0.2	Erosion of natural deposits or as a result of treatment with water additives
Calcium	NO	0.40-10.2	ppm	n/a	n/a	Erosion of natural deposits
Carbon Dioxide	NO	0.129-0.173	ppm	n/a	n/a	Naturally present in drinking water; sometimes added as water treatment to adjust pH
Chloride	NO	5.00-14.0	ppm	n/a	250	Naturally occurring in the environment or from runoff
Hardness	NO	ND-44.8	ppm	n/a	n/a	Naturally occurring in the environment or as a result of treatment with water additives
pH	NO	6.90-8.70	S.U.	n/a	6.5-8.5	Naturally occurring in the environment or as a result of treatment with water additives
Sodium	NO	60.0-119	ppm	n/a	n/a	Naturally occurring in the environment
Specific Conductance	NO	0.34-0.52	µmhos	n/a	n/a	Erosion of natural deposits or as a result of treatment with water additives
Sulfate	NO	14.8-47.7	ppm	n/a	250	Naturally occurring in the environment; erosion of natural deposits
Total Dissolved Solids	NO	184-282	ppm	n/a	500	Naturally occurring in the environment or as a result of industrial discharge or agricultural runoff

* One positive sample occurred on 3-7-18, and one occurred on 11-7-18. Follow-up sampling was performed as required, and all repeat samples and source water samples were negative. The positive samples *did not* cause an MCL or monitoring violation.

** Figure shown is 90th percentile, and number of sites above Action Level (AL) = 0

Special Monitoring Results

Distribution System Evaluation (DSE) Contaminants - 2018				
Contaminants	Violation Y/N	Level Detected	Unit Msmt.	Likely Source of Contamination
TTHM [Total trihalomethanes]	NO	ND-16.8	ppb	By-product of drinking water chlorination
HAA5 [Total haloacetic acids]	NO	ND-3.38	ppb	By-product of drinking water chlorination

Unregulated Contaminant Monitoring Rule 4 (UCMR4) Contaminants - 2018					
Contaminant	Unit Msmt	Level Detected	Contaminant	Unit Msmt	Level Detected
Germanium	ppb	ND-0.855	Tribufos	ppb	ND
Manganese	ppb	1.80-8.76	1-butanol	ppb	ND
Alpha-hexachlorocyclohexane	ppb	ND	2-methoxyethanol	ppb	ND
Chlorpyrifos	ppb	ND	2-propen-1-ol	ppb	ND
Dimethipin	ppb	ND	Butylated hydroxyanisole	ppb	ND
Ethoprop	ppb	ND	O-toluidine	ppb	ND
Oxyfluorfen	ppb	ND	Quinoline	ppb	0.051-0.632
Profenofos	ppb	ND	Total organic carbon (TOC)	ppb	ND
Tebuconazole	ppb	ND	Bromide	ppb	ND-89.4
Total permethrin (cis- & trans-)	ppb	ND			
Bromochloroacetic	ppb	0.306-0.796	Monobromoacetic	ppb	ND
Bromodichloroacetic	ppb	ND	Monochloroacetic	ppb	ND
Chlorodibromoacetic	ppb	ND	Tribromoacetic	ppb	ND
Dibromoacetic	ppb	ND-0.378	Trichloroacetic	ppb	ND
Dichloroacetic	ppb	0.429-1.55			

Definitions

Action Level (AL) - the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

Coliform Absent (ca) - Laboratory analysis indicates that the contaminant is not present.

Detected contaminant - any regulated or unregulated contaminant detected at or above its method detection limit (or reportable limit)

Disinfection by-products (DBPs) - are formed when disinfectants used in water treatment plants react with bromide and/or natural organic matter (i.e., decaying vegetation) present in the source water.

Distribution System Evaluation (DSE) - a one-year study conducted by water systems to monitor disinfection by-products.

Locational Running Annual Average (LRAA) - yearly average of all the DPB results at each specific sampling site in the distribution system. The range of lowest to highest distribution site LRAA is reported in the Table of Detected Contaminants.

Maximum Contaminant Level (MCL) - The MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water

Millirems per year (mrem/yr) - a measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present above detection limits of lab equipment.

Not Reported (NR) - laboratory analysis, usually Secondary Contaminants, not reported by water system. EPA recommends secondary standards to water systems but does not require systems to comply.

Parts per billion (ppb) or Micrograms per liter (µg/l) - corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) or Milligrams per liter (mg/l) - corresponds to one minute in two years or a single penny in \$10,000.

Parts per quadrillion (ppq) or Picograms per liter (pg/l) - corresponds to one minute in 2,000,000,000 years, or a single penny in \$10,000,000,000,000.

Parts per trillion (ppt) or Nanograms per liter (ng/l) - corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Primary Drinking Water Standards - legally enforceable primary standards and treatment techniques that protect public health by limiting the levels of contaminants in drinking water.

RAA - Running annual average - level reported is the highest RAA for the year

Secondary Drinking Water Standards - guidelines regulating contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water.

Standard Units (S.U.) - pH of water measures the water's balances of acids and bases and is affected by temperature and carbon dioxide gas. Water with less than 6.5 could be acidic, soft, and corrosive. A pH greater than 8.5 could indicate that the water is hard.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Unregulated Contaminant Monitoring Rule (UCMR) - EPA program to collect data for contaminants suspected to be present in drinking water, but that do not have health-based standards.

Variances & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Below is a list of *Primary Drinking Water Contaminants* for which we routinely monitor. These contaminants are monitored in accordance with sampling requirements established by EPA and ADEM; however, not all were detected in your drinking water. The contaminants that had some level of detection are listed in the table of *Detected Drinking Water Contaminants*.

STANDARD LIST OF PRIMARY DRINKING WATER CONTAMINANTS					
Contaminant	MCL	Unit of Msmt	Contaminant	MCL	Unit of Msmt
Bacteriological Contaminants					
Total Coliform Bacteria	<5%	present/absent	trans-1,2-Dichloroethylene	100	ppb
Fecal Coliform and E. coli	0	present/absent	Dichloromethane	5	ppb
Turbidity	TT	NTU	1,2-Dichloropropane	5	ppb
Cryptosporidium	TT	Calc.organisms/l	Di (2-ethylhexyl)adipate	400	ppb
Radiological Contaminants					
Beta/photon emitters	4	mrem/yr	Dinoseb	7	ppb
Alpha emitters	15	pCi/l	Dioxin [2,3,7,8-TCDD]	30	ppq
Combined radium	5	pCi/l	Diquat	20	ppb
Uranium	30	pCi/l	Endothall	100	ppb
Inorganic Chemicals					
Antimony	6	ppb	Epichlorohydrin	TT	TT
Arsenic	10	ppb	Ethylbenzene	700	ppb
Asbestos	7	MFL	Ethylene dibromide	50	ppt
Barium	2	ppm	Glyphosate	700	ppb
Beryllium	4	ppb	Heptachlor	400	ppt
Cadmium	5	ppb	Heptachlor epoxide	200	ppt
Chromium	100	ppb	Hexachlorobenzene	1	ppb
Copper	AL=1.3	ppm	Hexachlorocyclopentadiene	50	ppb
Cyanide	200	ppb	Lindane	200	ppt
Fluoride	4	ppm	Methoxychlor	40	ppb
Lead	AL=15	ppb	Oxamyl [Vydate]	200	ppb
Mercury	2	ppb	Polychlorinated biphenyls	0.5	ppb
Nitrate	10	ppm	Pentachlorophenol	1	ppb
Nitrite	1	ppm	Picloram	500	ppb
Selenium	.05	ppm	Simazine	4	ppb
Thallium	.002	ppm	Styrene	100	ppb
Organic Contaminants					
2,4-D	70	ppb	Toluene	1	ppm
Acrylamide	TT	TT	Toxaphene	3	ppb
Alachlor	2	ppb	2,4,5-TP(Silvex)	50	ppb
Benzene	5	ppb	1,2,4-Trichlorobenzene	.07	ppm
Benzo(a)pyrene [PAHs]	200	ppt	1,1,1-Trichloroethane	200	ppb
Carbofuran	40	ppb	1,1,2-Trichloroethane	5	ppb
Carbon tetrachloride	5	ppb	Trichloroethylene	5	ppb
Chlordane	2	ppb	Vinyl Chloride	2	ppb
Chlorobenzene	100	ppb	Xylenes	10	ppm
Disinfectants & Disinfection Byproducts					
Dalapon	200	ppb	Chlorine	4	ppm
Dibromochloropropane	200	ppt	Chlorine Dioxide	800	ppb
o-Dichlorobenzene	600	ppb	Chloramines	4	ppm
p-Dichlorobenzene	75	ppb	Bromate	10	ppb
1,2-Dichloroethane	5	ppb	Chlorite	1	ppm
1,1-Dichloroethylene	7	ppb	HAA5 [Total haloacetic acids]	60	ppb
cis-1,2-Dichloroethylene	70	ppb	TTHM [Total trihalomethanes]	80	Ppb
Atrazine	3	ppb			
Unregulated contaminants					
1,1 – Dichloropropene	Aldicarb	Chloroform	Metolachlor		
1,1,1,2-Tetrachloroethane	Aldicarb Sulfone	Chlorodibromomethane	Metribuzin		
1,1,2,2-Tetrachloroethane	Aldicarb Sulfoxide	Chloromethane Dibromomethane	N - Butylbenzene		
1,1-Dichloroethane	Aldrin	Hexachlorobutadiene	Naphthalene		
1,2,3 - Trichlorobenzene	Bromobenzene	Isopropylbenzene	N-Propylbenzene		
1,2,3 - Trichloropropane	Bromochloromethane	M-Dichlorobenzene	O-Chlorotoluene		
1,2,4 - Trimethylbenzene	Bromodichloromethane	Methomyl	P-Chlorotoluene		
1,3 – Dichloropropane	Bromoforn	MTBE	P-Isopropyltoluene		
1,3 – Dichloropropene	Bromomethane		Propachlor		
1,3,5 - Trimethylbenzene	Butachlor		Sec - Butylbenzene		
2,2 – Dichloropropane	Carbaryl		Tert - Butylbenzene		
3-Hydroxycarbofuran	Chloroethane		Trichlorofluoromethane		
Secondary contaminants					
Alkalinity, Total (as CA, CO ₃)	Copper	Magnesium	Silver		
Aluminum	Corrosivity	Manganese	Sodium		
Calcium, as Ca	Foaming agents (MBAS)	Odor	Sulfate		
Chloride	Hardness	Nickel	Total Dissolved Solids		
Color	Iron	pH	Zinc		